

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No: 3775-1305:118 Page 1 of 1

CATEGORY: Manual Locks

LISTEE: Corbin Russwin, 225 Episcopal Rd., Berlin CT 06037
Contact: Pradip Basu (860) 828-7377

DESIGN: CORBIN RUSSWIN Single point lock Model UT5200 series. Refer to listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: UL label and fire rating.

APPROVAL: Listed as single manual lock with a maximum fire rating of 3 hours. Limited to installation in single swing doors not exceeding 7'-2" high/3'-8" wide, pair swinging doors not exceeding 7'-2" high and 7'4" wide. Approved for installation in doors up to 1-1/2 hour fire rated in sizes of single door not exceeding 8' high and 4' wide and pairs not exceeding 8' high and 8' wide.

NOTE: Formerly 3775-0522:100

*Rev. 05-18-94



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 5, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager